



City of Moore Oklahoma

Office of the City Manager | 301 N. Broadway, Moore, OK 73160 | (405) 793-5200 | www.cityofmoore.com

March 26, 2023

Emily Hoskin
Compliance Coordinator
Water Quality Division
Department of Environmental Quality P.O. Box 1677
Oklahoma City, OK 73101-1677

Re: NOV No. P-2001412-23-1

WL023, Well# 24

Moore Public Water Supply

PWSID No. OK2001412

NOV for WL023 Fourth Quarter 2022 Arsenic Concentration (0.014 MG/L)

The well was turned off during the time of the Notification of Violation (NOV) and not being used at this time. We have been waiting for results of a pilot study and approval of a treatment system for arsenic removal. This will be installed at the well and before entrance into the distribution system. If further sampling is needed before the removal system is approved and installed, the well will be sampled going to waste and not at the site of the City of Moore's distribution system.

Per the conversation between you and Steve Rea, we will place public notification in the May citywide newsletter, mailed to all customer utility accounts, as well as on the City's website.

If you need more information, please contact Steve Rea at 405-313-8054

Thanks,

A handwritten signature in black ink that reads "Brooks Mitchell".

Brooks Mitchell
City Manager
City of Moore, Oklahoma